Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 548 Dated: 02/02/2026.

It is certified that an inspection team headed by Gr: Mohit Kumar (AE) / Amita Devi (Chemist)

(Name of Officers with designation) from U.P.Jal Nigam Agra .....PHED

inspected the Delhi Public Internation School Jal Semri, Deori Road Agra.

(Name & Address of the school) on 27/01/2026....(date of inspection) and on the basis of Water Test Report (Attached) bearing no. UPJN/AGR/26/01/548 dated. 02/02/2026 of Regional Water testing Laboratory Agra (PHED Lab) certified that the Delhi Public International School....(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ...one year...

Signature with Seal: .....

Name : ...Mohit Kumar.....

Designation : ...AE.....

Name & Address of the Office / Department : U.P. Jal Nigam (Gramin) Agra.

सहायक अभियन्ता
खण्ड कार्यालय
उ0प्र0 जल निगम (ग्रामीण)
आगरा

Amita

To

Principal

Delhi Public International School

(Name & Address of the Institution) Agra.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

* Sample will stored up to 07 days from the date of Issue report.

Amit

0-

Note. Sample Collected by Delhi Public School.

Regional Water Testing Laboratory

Address: 4/4 Sanjay Place U.P. JalNigam(Rural) Agra, 282002

TC-9960

TEST REPORT					
Report No:	UPJN/AGR/26/01/548	Issue Date:	02/02/2026	Page No	1/2

Customer Details			
Office Name and Address	Delhi Public International School & Tal Semri Deori Road Agra (282001)		
Ref Letter No & Date	NA& 28/01/2026		
	Basic details of sample		
		Block/City	Barauli Ahir
District	Agra	Village/city	Tal Semri
Gram Panchayat	-	Location	Delhi public International School
Water Source	RO water	Sample No.	01
Quantity of Sample	1 Lt.	Date of Collection	27/01/2026
Receiving Date	28/01/2026	S. Collector	Mr.Keshav kumar
Sample Depositor	Mr.Keshav kumar	Sampling Method	As per IS 17614: Part 1: 2021
Analysis Start Date	30/01/2026	Analysis Completion Date:	30/01/2026

Technical Data of Analysis

S.No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500:2012		Ref. Method of Analysis Joint testing(100-130
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25◦C)	7.38	6-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity NTU	1.25	1	5	IS 3025 (Pt 10):1984 (Nephelometric Method)
3	Total Dissolved Solid mg/L	90.2	500	2000	IS 3025 (Pt 16):1984 (Gravimetric Method)
4	Fluoride mg/L	0.748	1	1.5	APHA 24rd Edition 4500-F Method C (Electrode method) 2017
5	Total Hardness mg/L	16	200	600	IS 3025 (Part 21):2009(EDTA Method)
6	Total Alkalinity mg/L	24	200	600	IS 3025 (Part 23):1986 (Potentiometric method)
7	Chloride mg/L	20	250	1000	IS 3025 (Part 32):1988 (Argentometric method)
8	Iron mg/L	--	1	1	APHA 24rd Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate mg/L	Nil	200	400	APHA 24rd Edition 4500-SO4 Method E (Turbidity Method) 2017
10	Calcium mg/L	12	75	200	IS 3025 (Part 40):1991(EDTA Titrimetric Method)
11	Magnesium mg/L	1.72	30	100	IS 3025 (Part 46):1994(Volumetric Method)

12	Color (Hazen)	1	5	15	APHA 24rd Edition Color 2120 B (Visual Comparison Method)
13	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (PART 08) 1984 (Qualitative Method)
14	Nitrate (mg/l)	Nil	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Prepared by

Amita

(Amita Devi)
Authorized Signatory:
Testing Lab In charge

Regional Water Testing Laboratory (R) Agra QUALITY MANAGER

Laboratory Contact details
Mob. (8630905287)

----------End of Report----------

Analysis Report

Regional Water Testing Laboratory

Address :4/4 Sanjay Palace U.P. Jal Nigam(Rural), Agra, 282002

Report No.	Agr/micro/86/2025-26	Issue Date:	02/02/2026		
Remark	Pass			Page No	1
Contact Person:	Amita Devi	Address:	UPJN Agra	Mob:	8630905287

Customer Details

Office Name and Address	**M/S** Delhi Public International School Tal Semri ,Deori Road, Agra 282001
Ref Letter No & Date	NA

Basic details of sample

District	Agra	Block/city	Barauli Ahir
Gram Panchayat	-	Village/Mohalla	Tal Semri
Habitation	-	Location	Delhi Public School
Water Source	RO Water	Sample No.	01
Quantity of Sample	1 L	Date of Collection	26/01/2026
Receiving Date	26/01/2026	S. Collector	Mr. Keshav Kumar
Sample Depositor	Mr. Keshav Kumar	Sampling Method	IS 1622 : 1981
Analysis Start Date	27/01/2026	Analysis Completion Date:	29/01/2026

Technical Data of Analysis

S.No	Analyzed parameters	Unit of Measurement	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2		3	4	5	6
1	pH	-	7.08	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Total Coliform	CFU/100 ml	00	No Relaxation	No Relaxation	IS 15185:2016
3	E.Coli	CFU/100 ml	00	No Relaxation	No Relaxation	IS 15185 : 2016

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Aditya Kumar Singh
(Microbiologist)

Amita Devi
(Lab In-Charge)

Laboratory Contact details
Email- regionalwatertestinglabagra@gmail.com